

2022



Electrical Equipment Safety Report

Why not try our other services?

- **Lighting Projects**
- **Electrical Testing**
- **Emergency Lighting**
- **Electrical Repairs**
- **Residual Current Devices (RCDs)**
- **Electrical Equipment Testing and many more services...**

For more information, please feel free to visit our website or contact us.

** In case of requests made by a Health & Safety Inspector or Local Authority Enforcement Officer, please ensure that these records are accessible.*

 www.actest.co.uk





This Certificate was supplied by National Test Services

To Certify

ST ANDREWS CHURCH

SILVER STREET

ENFIELD

EN1 3EG

Portable Appliance Testing

With a total of 84 items tested

04/11/2022

National Test Services Limited. Registered in England & Wales No. 446 3541 Vat No. 793-8483-68

Director and Company Secretary Terence Woods



Datasheet Number: **DTA25436**

Job No. **27102237**

Date **04/11/2022**

Site **ST ANDREWS CHURCH**

Unit 80,
Barwell Business Park,
Chessington,
KT9 2NY

Tel: 01452 505066
Fax: 01452 505664
Email: Sales@nts.uk.net
www.nts.uk.net

8 November 2022

Asset Tag	Item Desc	Room/Area	Location	EC	Earth	INS	LC	VOC	Engineer	Site	Date	RF	PC	FC	VF	MEF	Notes
14142501	POWER SUPPLY UNIT CLASS 2	AV STUDIO	1ST FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142502	EXTENSION LEAD	AV STUDIO	1ST FLOOR	.2A	0.19 ohm P	>19.99 Mohm	P	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142503	EXTENSION LEAD	AV STUDIO	1ST FLOOR	.2A	0.18 ohm P	>19.99 Mohm	P	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142504	POWER SUPPLY UNIT CLASS 2	AV STUDIO	1ST FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142505	IEC LEAD	AV STUDIO	1ST FLOOR	.2A	0.07 ohm P	>19.99 Mohm	P	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142506	POWERED SPEAKER	AV STUDIO	1ST FLOOR	.2A	0.18 ohm P	>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142507	CLASS 2 LEAD	AV STUDIO	1ST FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142508	POWER SUPPLY UNIT CLASS 2	AV STUDIO	1ST FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142509	IEC LEAD	AV STUDIO	1ST FLOOR	.2A	0.05 ohm P	>19.99 Mohm	P	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142510	POWERED SPEAKER	AV STUDIO	1ST FLOOR	.2A	0.15 ohm P	>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142511	EXTENSION LEAD	AV STUDIO	1ST FLOOR	.2A	0.15 ohm P	>19.99 Mohm	P	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142512	EXTENSION LEAD	AV STUDIO	1ST FLOOR	.2A	0.16 ohm P	>19.99 Mohm	P	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142513	POWER SUPPLY UNIT CLASS 2	AV STUDIO	1ST FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142514	POWER SUPPLY UNIT CLASS 2	AV STUDIO	1ST FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142515	CLASS 2 LEAD	AV STUDIO	1ST FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142516	POWER SUPPLY UNIT CLASS 2	AV STUDIO	1ST FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142517	CLASS 2 LEAD	AV STUDIO	1ST FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142518	POWER SUPPLY UNIT CLASS 2	AV STUDIO	1ST FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	



Unit 80,
Barwell Business Park,
Chessington,
KT9 2NY

Tel: 01452 505066
Fax: 01452 505664
Email: Sales@nts.uk.net
www.nts.uk.net

8 November 2022

Asset Tag	Item Desc	Room/Area	Location	EC	Earth	INS	LC	VOC	Engineer	Site	Date	RF	PC	FC	VF	MEF	Notes
14142519	CLASS 2 LEAD	AV STUDIO	1ST FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142520	POWER SUPPLY UNIT CLASS 2	AV STUDIO	1ST FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142521	CLASS 2 LEAD	AV STUDIO	1ST FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142522	POWER SUPPLY UNIT CLASS 2	AV STUDIO	1ST FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142523	CLASS 2 LEAD	AV STUDIO	1ST FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142524	POWER SUPPLY UNIT CLASS 2	AV STUDIO	1ST FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142525	CLASS 2 LEAD	AV STUDIO	1ST FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142526	POWER SUPPLY UNIT CLASS 2	AV STUDIO	1ST FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142527	CLASS 2 LEAD	AV STUDIO	1ST FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142528	POWER SUPPLY UNIT CLASS 2	AV STUDIO	1ST FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142547	IEC LEAD	CHURCH BUILDING	GRD FLOOR	.2A	0.07 ohm P	>19.99 Mohm	P	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142548	AMPLIFIER	CHURCH BUILDING	GRD FLOOR	.2A	0.15 ohm P	>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142549	AMPLIFIER	CHURCH BUILDING	GRD FLOOR	.2A	0.16 ohm P	>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142550	AMPLIFIER	CHURCH BUILDING	GRD FLOOR	.2A	0.12 ohm P	>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142551	HEATER CLASS 1	CHURCH BUILDING	GRD FLOOR	.2A	0.12 ohm P	>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142552	EXTENSION LEAD	CHURCH BUILDING	GRD FLOOR	.2A	0.15 ohm P	>19.99 Mohm	P	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142553	POWER SUPPLY UNIT CLASS 2	CHURCH BUILDING	GRD FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142554	AMPLIFIER	CHURCH BUILDING	GRD FLOOR	.2A	0.11 ohm P	>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	



Unit 80,
Barwell Business Park,
Chessington,
KT9 2NY

Tel: 01452 505066
Fax: 01452 505664
Email: Sales@nts.uk.net
www.nts.uk.net

8 November 2022

Asset Tag	Item Desc	Room/Area	Location	EC	Earth	INS	LC	VOC	Engineer	Site	Date	RF	PC	FC	VF	MEF	Notes
14142555	EXTENSION LEAD	CHURCH BUILDING	GRD FLOOR	.2A	0.16 ohm P	>19.99 Mohm	P	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142556	POWER SUPPLY UNIT CLASS 2	CHURCH BUILDING	GRD FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142557	LOOP AID	CHURCH BUILDING	GRD FLOOR	.2A	0.15 ohm P	>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142558	HEATER CLASS 1	CHURCH BUILDING	GRD FLOOR	.2A	0.12 ohm P		S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142559	HEATER CLASS 1	CHURCH BUILDING	GRD FLOOR	.2A	0.11 ohm P		S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142560	HEATER CLASS 1	CHURCH BUILDING	GRD FLOOR	.2A	0.17 ohm P		S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142561	HEATER CLASS 1	CHURCH BUILDING	GRD FLOOR	.2A	0.17 ohm P		S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142562	HEATER CLASS 1	CHURCH BUILDING	GRD FLOOR	.2A	0.15 ohm P		S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142563	EXTENSION LEAD	CHURCH BUILDING	GRD FLOOR	.2A	0.12 ohm P	>19.99 Mohm	P	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142564	POWER SUPPLY UNIT CLASS 2	CHURCH BUILDING	GRD FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142565	EXTENSION LEAD	CHURCH BUILDING	GRD FLOOR	.2A	0.11 ohm P	>19.99 Mohm	P	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142566	IEC LEAD	CHURCH BUILDING	GRD FLOOR	.2A	0.07 ohm P	>19.99 Mohm	P	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142567	CONTROL DESK	CHURCH BUILDING	GRD FLOOR	.2A	0.12 ohm P	>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142568	POWER SUPPLY UNIT CLASS 2	CHURCH BUILDING	GRD FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142569	POWER SUPPLY UNIT CLASS 2	CHURCH BUILDING	GRD FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142570	LAMP CLASS 2	CHURCH BUILDING	GRD FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142571	KEYBOARD	CHURCH BUILDING	GRD FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142572	VACUUM CLEANER CLASS 2	CHURCH BUILDING	GRD FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	



Unit 80,
Barwell Business Park,
Chessington,
KT9 2NY

Tel: 01452 505066
Fax: 01452 505664
Email: Sales@nts.uk.net
www.nts.uk.net

8 November 2022

Asset Tag	Item Desc	Room/Area	Location	EC	Earth	INS	LC	VOC	Engineer	Site	Date	RF	PC	FC	VF	MEF	Notes
14142573	VACUUM CLEANER CLASS 2	CHURCH BUILDING	GRD FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142574	EXTENSION LEAD	CHURCH BUILDING	GRD FLOOR	.2A	0.19 ohm P	>19.99 Mohm	P	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142575	COFFEE MAKER CLASS 1	CHURCH BUILDING	GRD FLOOR	.2A	0.17 ohm P	>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142576	COFFEE MAKER CLASS 1	CHURCH BUILDING	GRD FLOOR	.2A	0.15 ohm P	>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142577	HEATER CLASS 1	CHURCH BUILDING	GRD FLOOR	.2A	0.16 ohm P	>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142578	COFFEE MAKER CLASS 1	CHURCH BUILDING	GRD FLOOR	.2A	0.16 ohm P	>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142579	EXTENSION LEAD WITH BREAKER	CHURCH BUILDING	GRD FLOOR	.2A	0.10 ohm P	>19.99 Mohm	P	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142580	EXTENSION LEAD	CHURCH BUILDING	GRD FLOOR	.2A	0.18 ohm P	>19.99 Mohm	P	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142581	EXTENSION LEAD	CHURCH BUILDING	GRD FLOOR	.2A	0.15 ohm P	>19.99 Mohm	P	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142582	EXTENSION LEAD	CHURCH BUILDING	GRD FLOOR	.2A	0.16 ohm P	>19.99 Mohm	P	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142583	WATER BOILER	CHURCH BUILDING	GRD FLOOR	.2A	0.12 ohm P	>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142584	HEATER CLASS 1	CHURCH BUILDING	GRD FLOOR	.2A	0.12 ohm P		S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142529	EXTENSION LEAD	OFFICE 1	GRD FLOOR	.2A	0.10 ohm P	>19.99 Mohm	P	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142530	POWER SUPPLY UNIT CLASS 2	OFFICE 1	GRD FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142531	POWER SUPPLY UNIT CLASS 2	OFFICE 1	GRD FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142532	CLASS 2 LEAD	OFFICE 1	GRD FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142533	PRINTER CLASS 2	OFFICE 1	GRD FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142534	POWER SUPPLY UNIT CLASS 2	OFFICE 1	GRD FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	



Unit 80,
Barwell Business Park,
Chessington,
KT9 2NY

Tel: 01452 505066
Fax: 01452 505664
Email: Sales@nts.uk.net
www.nts.uk.net

8 November 2022

Asset Tag	Item Desc	Room/Area	Location	EC	Earth	INS	LC	VOC	Engineer	Site	Date	RF	PC	FC	VF	MEF	Notes
14142535	LAMP CLASS 1	OFFICE 1	GRD FLOOR	.2A	0.19 ohm P	>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142536	POWER SUPPLY UNIT CLASS 2	OFFICE 1	GRD FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142537	LAMINATOR CLASS 2	OFFICE 1	GRD FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142538	IEC LEAD	OFFICE 2	GRD FLOOR	.2A	0.06 ohm P	>19.99 Mohm	P	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142539	PHOTOCOPIER	OFFICE 2	GRD FLOOR	.2A	0.16 ohm P	>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142540	IEC LEAD	OFFICE 2	GRD FLOOR	.2A	0.08 ohm P	>19.99 Mohm	P	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142541	CPU/VDU COMBI	OFFICE 2	GRD FLOOR	.2A	0.11 ohm P	>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142542	SHREDDER CLASS 2	OFFICE 2	GRD FLOOR	.2A		>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142543	HEATER CLASS 1	THE HAVEN	GRD FLOOR	.2A	0.11 ohm P	>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142544	KETTLE BASE	THE HAVEN	GRD FLOOR	.2A	0.17 ohm P	>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142545	KETTLE	THE HAVEN	GRD FLOOR	.2A	0.11 ohm P	>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	
14142546	COFFEE MAKER CLASS 1	THE HAVEN	GRD FLOOR	.2A	0.17 ohm P	>19.99 Mohm	S	No	J.B	27102237	04/11/2022	12	No	No	No	No	

84 total tests, 84 full tests, 0 visual tests, 0 microwave emissions tests, 0 failed tests



Unit 80,
Barwell Business Park,
Chessington,
KT9 2NY

Tel: 01452 505066

Fax: 01452 505664

Email: Sales@nts.uk.net

www.nts.uk.net

8 November 2022

Key :

EC - Test current

Earth - Earth test

INS - Insulation test

VOC - Visual inspection only

RF - Retest frequency

PC - Plug changed

FC - Fuse changed

VF - Visual inspection failure

MEF - Microwave emission failure

S - Test not required

F - Appliance has failed during test

P - Pass