

This inspection is for gas safety purposes only to comply with the Gas Safety (Installation and Use) Regulations. Flues have been inspected visually and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the flue integrity, construction and lining has NOT been carried out.

REGISTERED BUSINESS DETAILS

Reg No: 216825

Company: Willingham Bros

Address: 11 GRADSTONE ROAD
DANE END HERTS

Postcode: SG12 0NH

Tel: 07530 390 939

INSPECTION/INSTALLATION ADDRESS

Name & Title: ST ANDREWS Church

Address: 18 SILVER STREET
ENFIELD
MIDDLESEX

Postcode: EN1 3EG Tel: _____

LANDLORD (OR AGENT) NAME & ADDRESS (if applicable)

Name & Title: _____

Address: _____

Postcode: _____ Tel: _____

Number of appliances tested: _____

APPLIANCE DETAILS							FLUE TESTS				INSPECTION DETAILS							
	Location	Make and Model	Type	Flue Type OF/RS/FL	Operating pressure in mbar or heat input kW/h or Btu/h	Safety device(s) correct operation Yes/No/NA	Spillage test Pass/Fail/NA	Smoke pellet flue flow test Pass/Fail/NA	Initial combustion analyser reading	Final combustion analyser reading	Satisfactory termination Yes/No/NA	Flue visual condition Pass/Fail/NA	Adequate ventilation Yes/No	Landlord's appliance Yes/No/NA	Inspected Yes/No	Appliance Visual Check Yes/No	Appliance serviced Yes/No	Appliance Safe to Use Yes/No
1	<u>TOILETS</u>	<u>IDEAL ECOMAX</u>	<u>B2 RS</u>	<u>20m</u>	<u>YES</u>	<u>PASS</u>	<u>NA</u>	<u>-</u>	<u>9000</u>	<u>YES</u>	<u>PASS</u>	<u>YES</u>	<u>YES</u>	<u>YES</u>	<u>YES</u>	<u>YES</u>	<u>YES</u>	<u>YES</u>
2																		
3																		
4																		
5																		

For appliances not owned by the landlord the recorded 'Appliance Safe to Use' response is based on a visual check for obvious defects only

Gas Installation Pipework: Satisfactory Visual Inspection: Yes ☒ No ☐ Emergency Control Accessible: Yes ☒ No ☐ Satisfactory Gas Tightness Test: Yes ☒ No ☐ Equipotential Bonding Satisfactory: Yes ☒ No ☐

GIVE DETAILS OF ANY FAULTS					RECTIFICATION WORK CARRIED OUT					WARNING NOTICE ISSUED Yes/No/NA	WARNING TAG or LABEL FIXED Yes/No/NA
1	<u>AUTO AIR LEAK IN THE BOILER</u>										
2											
3											
4											
5											

Audible CO Alarms: Approved CO Alarms Fitted: Yes ☐ No ☐ N/A ☐ Are CO Alarms in Date: Yes ☐ No ☐ N/A ☐ Testing of CO Alarms Satisfactory: Yes ☐ No ☐ N/A ☐ Smoke Alarms Fitted: Yes ☐ No ☐ N/A ☐

OTHER COMMENTS OR OBSERVATIONS

NEXT GAS SAFETY CHECK DUE BEFORE:

4/11/23

ISSUED BY (GAS ENGINEER)

Print Name: K. Willingham Signed: _____

Licence No: 5348763 Issue Date: 4.11.22

RECEIVED BY

(Delete as applicable) Tenant/Agent/Landlord/Home Owner No one present at time of visit ☒

Received By: _____ Signed: _____ Print Name: _____